## § 154.806

## § 154.806 Application for acceptance as a certifying entity.

- (a) An individual or organization seeking acceptance as a certifying entity must apply in writing to the Commandant (Stop 7363, Washington, DC 20593-7363). Each application must be signed and certified to be correct by the applicant or, if the applicant is an organization, by an authorized officer or official representative of the organization, and must include a letter of intent from a facility owner or operator to use the services of the individual or organization to certify a vapor control system installation. Any false statement or misrepresentation, or the knowing and willful concealment of a material fact may subject the applicant to prosecution under the provisions of 18 U.S.C. 1001, and denial or termination of acceptance as a certifving entity.
- (b) The applicant must possess the following minimum qualifications, and be able to demonstrate these qualifications to the satisfaction of the Commandant (Stop 7363, Washington, DC 20593–7363):
- (1) The ability to review and evaluate design drawings and failure analyses;
- (2) A knowledge of the applicable regulations of this subpart, including the standards incorporated by reference in these regulations;
- (3) The ability to monitor and evaluate test procedures and results;
- (4) The ability to perform inspections and witness tests of bulk liquid cargo handling systems:
- (5) That it is not controlled by an owner or operator of a vessel or facility engaged in controlling vapor emissions; and
- (6) That it is not dependent upon Coast Guard acceptance under this section to remain in business.
- (c) Each application for acceptance must contain the following:
- (1) The name and address of the applicant, including subsidiaries and divisions if applicable;
- (2) A statement that the applicant is not controlled by an owner or operator of a vessel or facility engaged in controlling vapor emissions, or a full disclosure of any ownership or controlling interest held by such owners or operators;

- (3) A description of the experience and qualifications of the person(s) who would be reviewing or testing the systems:
- (4) A statement that the person(s) who would be reviewing or testing the systems is/are familiar with the regulations in this subpart; and
- (5) A statement that the Coast Guard may verify the information submitted in the application and may examine the person(s) who would be reviewing or testing the systems to determine their qualifications.
- (d) The acceptance of a certifying entity may be terminated by the Commandant (Stop 7363, Washington, DC 20593-7363) if the entity fails to properly review, inspect, or test a system in accordance with this subpart.

NOTE: A list of entities accepted to certify facility vapor control system installations is available from the Commandant (Stop 7363, Washington, DC 20593-7363).

(Approved by the Office of Management and Budget under control number 1625-0060)

[CGD 88–102, 55 FR 25429, June 21, 1990, as amended by CGD 96–026, 61 FR 33666, June 28, 1996; USCG–2006–25150, 71 FR 39210, July 12, 2006; USCG–2010–0351, 75 FR 36284, June 25, 20101

## §154.808 Vapor control system, general.

- (a) A vapor control system design and installation must eliminate potential overfill hazards, overpressure and vacuum hazards, and sources of ignition to the maximum practical extent. Each remaining hazard source which is not eliminated must be specifically addressed in the protection system design and operational requirements.
- (b) Vapor collection system piping and fittings must be in accordance with ANSI B31.3 (incorporated by reference; see §154.106) and designed for a maximum allowable working pressure of at least 150 psig. Valves and flanges must be in accordance with ANSI B16.5 or B16.24 (both incorporated by reference; see §154.106), 150 pound class.
- (c) All electrical equipment used in a vapor control system must comply with NFPA 70.
- (d) Any pressure, flow, or concentration indication required by this part must provide a remote indicator on the

facility where the cargo transfer and vapor control systems are controlled.

- (e) Any alarm condition specified in this part must activate an audible and visible alarm where the cargo transfer and vapor control systems are controlled.
- (f) The vapor control system must be separated or insulated from external heat sources to limit vapor control system piping surface temperature to not more than 177 °C. (350 °F.) during normal operation.
- (g) A means must be provided to eliminate any liquid condensate from the vapor collection system which carries over from the vessel or condenses as a result of an enrichment process.
- (h) If a liquid knockout vessel is installed it must have:
- (1) A means to indicate the level of liquid in the device;
- (2) A high liquid level sensor that activates an alarm; and
- (3) A high high level sensor that closes the remotely operated cargo vapor shutoff valve required by \$154.810(a) of this subpart and shuts down any compressors or blowers prior to liquid carrying over from the vessel to the compressor or blower.
- (i) Vapor collection piping must be electrically grounded and electrically continuous.
- (j) If the facility handles inerted vapors of cargoes containing sulfur, provisions must be made to control heating from pyrophoric iron sulfide deposits in the vapor collection line.

[CGD 88–102, 55 FR 25429, June 21, 1990, as amended by USCG–2001–8661, 74 FR 45023, Aug. 31, 2009]

## § 154.810 Vapor line connections.

- (a) A remotely operated cargo vapor shutoff valve must be installed in the vapor collection line between the facility vapor connection and the nearest point where any inerting, enriching, or diluting gas is introduced into the vapor collection line or where a detonation arrester is fitted. The valve must:
- (1) Close within thirty (30) seconds after detection of a shutdown condition by a component required by this subpart;
- (2) Close automatically if the control signal is lost;

- (3) Activate an alarm when a signal to shut down is received:
- (4) Be capable of manual operation or manual activation;
- (5) Have a local valve position indicator or be designed so that the valve position can be readily determined from the valve handle or valve stem position; and
- (6) If the valve seat is fitted with resilient material, not allow appreciable leakage when the resilient material is damaged or destroyed.
- (b) Except when a vapor collection arm is used, the last 1.0 meter (3.3 feet) of vapor piping before the facility vapor connection must be:
  - (1) Painted red/yellow/red with:
- (i) The red bands 0.1 meter (0.33 feet) wide, and
- (ii) The middle yellow band 0.8 meter (2.64 feet) wide; and
- (2) Labeled "VAPOR" in black letters at least 50 millimeters (2 inches) high.
- (c) Each facility vapor connection flange must have a permanently attached 0.5 inch diameter stud at least 1.0 inch long projecting outward from the flange face. The stud must be located at the top of the flange, midway between bolt holes, and in line with the bolt hole pattern.
- (d) Each hose used for transferring vapors must:
- (1) Have a design burst pressure of at least 25 psig;
- (2) Have a maximum allowable working pressure of at least 5 psig;
- (3) Be capable of withstanding at least 2.0 psi vacuum without collapsing or constricting;
- (4) Be electrically continuous with a maximum resistance of ten thousand (10.000) ohms:
  - (5) Have flanges with:
- (i) A bolt hole arrangement complying with the requirements for 150 pound class ANSI B16.5 (incorporated by reference; see § 154.106) flanges, and
- (ii) One or more 0.625 inch diameter holes in the flange located midway between bolt holes and in line with the bolt hole pattern;
- (6) Be abrasion resistant and resistant to kinking; and
- (7) Have the last 1.0 meter  $(3.3\ \text{feet})$  of each end of the vapor hose marked in accordance with paragraph (b) of this section.